


CABLE RACK, 90° OUTSIDE BEND, CHANNEL TYPE

Modified:09/22/2009



Ordering Table	1-1/2" side bar (A)	2" side bar (A)	width (w)
	00200701xx	00200716xx	5"
	00200702xx	00200717xx	6"
	00200703xx	00200718xx	9"
	00200704xx	00200719xx	10"
	00200705xx	00200720xx	11"
	00200706xx	00200721xx	12"
	00200707xx	00200722xx	15"
	00200708xx	00200723xx	18"
	00200709xx	00200724xx	20"
	00200710xx	00200725xx	21"
	00200711xx	00200726xx	24"
	00200712xx	00200727xx	25"
	00200713xx	00200728xx	27"
	00200714xx	00200729xx	30"
	00200715xx	00200730xx	36"

Notes:

- XX = finish code; standard finish, XX = 30.
- Certified as meeting National Electric Code (NEC) requirements for use as an Equipment Grounding Conductor [NEC article 318-7; table 318-7 (b) (2)]. Certification label must not be removed.
- Material: steel 1-1/2" Solid side bar equipment grounding conductor (EGC) cross-section equals 1.12 square inches 2" Solid side bar Equipment Grounding Conductor (EGC) cross-section equals 1.50 Square inches.