


**CABLE RACK, 30° DROP OFF, BAR TYPE**

Modified:09/22/2009



	1-1/2" side bar (A)	2" side bar (A)	width (w)
<b>Ordering Table</b>	00200901xx	00200916xx	5"
	00200902xx	00200917xx	6"
	00200903xx	00200918xx	9"
	00200904xx	00200919xx	10"
	00200905xx	00200920xx	11"
	00200906xx	00200921xx	12"
	00200907xx	00200922xx	15"
	00200908xx	00200923xx	18"
	00200909xx	00200924xx	20"
	00200910xx	00200925xx	21"
	00200911xx	00200926xx	24"
	00200912xx	00200927xx	25"
	00200913xx	00200928xx	27"
	00200914xx	00200929xx	30"
	00200915xx	00200930xx	36"

**Notes:**

- XX = finish code; standard finish, XX = 30.
- Certified as meeting National Electric Code (NEC) requirements for use as an equipment grounding conductor [NEC article 318-7; table 318-7 (b) (2)]; file number E112147. Certification label must not be removed.
- Material: steel 1-1/2" Solid side bar Equipment Grounding Conductor (EGC) cross-section equals 1.12 Square inches.