


CABLE RACK, 300 DROP OFF, CHANNEL TYPE

Modified:03/25/2014



Notes:

- XX = finish code; standard finish, XX = 30.
- Certified as meeting National Electric Code (NEC) requirements for use as an equipment grounding conductor [NEC article 318-7; table 318-7 (b) (2)]; file number E112147. Certification label must not be removed.
- Material: steel 1-1/2" Solid side bar Equipment Grounding Conductor (EGC) cross-section equals 1.12 Square inches.

Ordering Table

1-1/2" side bar (A)	2" side bar (A)	Width (W)
00201001xx	00201016xx	5"
00201002xx	00201017xx	6"
00201003xx	00201018xx	9"
00201004xx	00201019xx	10"
00201005xx	00201020xx	11"
00201006xx	00201021xx	12"
00201007xx	00201022xx	15"
00201008xx	00201023xx	18"
00201009xx	00201024xx	20"
00201010xx	00201025xx	21"
00201011xx	00201026xx	24"
00201012xx	00201027xx	25"
00201013xx	00201028xx	27"
00201014xx	00201029xx	30"
00201015xx	00201030xx	36"