
INSTRUMENT COMPANY Phone: (919) 575-6426 Fax: (919) 575-4708 www.eNewton.com

Modified:09/22/2009

INSULATING JUNCTION FOR CABLE RACK



	part number			CR side bar
bu	0021150010			1-1/2″
Ordering	002	1150110	0	2″
	Item	Qty	D	escription
st	Item 1	Qty 2		escription sulator
k List			in	· ·
Stock List	1	2	in sp	sulator

- Notes: Finish is zinc plated and gold chromate
- Insulator material is rated U.L 94 V-1 and has an oxygen index rating of greater than 29.