


INSULATOR PAD FOR UNEQUAL FLANGE EQUIPMENT RACK

Modified:09/25/2009



Notes:

- Insulator material is rated ul 94 v-1 and has an oxygen index rating of greater than 29.

| | | part number | A | B |
|-----------------------|--|-------------|---------|-----------|
| Ordering Table | | 0041170010 | 9-7/16" | 21-11/16" |
| | | 0041180010 | 9-7/16" | 25-11/16" |
| | | | | |

| | | Item | Qty | Description |
|-------------------|--|------|-----|------------------|
| Stock List | | 1 | 1 | base insulator |
| | | 2 | 4 | bushing |
| | | 3 | 4 | 1/2" flat washer |